



CALL 48 HOURS BEFORE YOU DIG – Dial 811
It shall be the Member’s responsibility to stay
clear of all underground facilities.

NOTICE

The Cooperative recommends that all work on the Member’s facilities be performed by a qualified, licensed electrical contractor.

Notes:

1. Member facilities shall comply with Cooperative Standards, the National Electrical Code, and authorities having jurisdiction.
2. Buildings or other facilities shall not be constructed over existing Cooperative supply lines, nor shall any Cooperative supply lines pass under existing buildings or facilities.
3. Schedule 80 PVC for elbows and above ground facilities are required. Also see drawings XXXX and XXXX.
4. Main breaker should be within 2'-0" of meter. Outside wall is recommended.
5. Member shall install meter enclosure.
6. Minimum 3 ft. clearance between electric meter and gas meter.
7. For grounding information see section 11.5.
8. Any Service greater than 320 amps, consult the Cooperative.

**TYPICAL FLOOD PLAIN RAISED
 FOUNDATION METER ACCESS
 REQUIREMENTS**

UNDERGROUND SOURCE

DRAWING 11.7-2

August 2010
 NOT TO SCALE

