




The Cooperative will not install electrical wires or facilities over a pool, shed, or deck.



CAUTION :
If trees, structures, or other obstructions interfere with the overhead service line, the obstruction must be removed, or the connection points may need to be relocated or the service line converted to underground (if possible) at the Member's expense.

Maximum Recommended Distance from Cooperative Pole to Structure	
Amps	Distance (feet)
100	100
200	75
320	40

CALL 48 HOURS BEFORE YOU DIG – Dial 811
It shall be the Member's responsibility to stay clear of all underground facilities.

- Notes:
1. NEVER build anything over or under electrical lines or facilities. Check with Cooperative for clearances.
 2. Contact Cooperative for clearances prior to pool construction (NEC Table 234-2 and NEC 680.6).
 3. See Section 11.5 for meter location.
 4. Connection point shall be pre-approved by the Cooperative.

OVERHEAD METER ON HOUSE

INSTALLATION DETAILS

DRAWING 7.2-1

August 2010
NOT TO SCALE

