



WRONG POSITION TO SET METER PEDESTAL

SEE CAUTION 1




METER PEDESTAL SET CORRECTLY




CAUTION 1: Maximum length is 200'. For longer lengths, consult with the Cooperative (see note 3). Excess length may involve additional cost to the Member.

WRONG POSITION TO SET METER PEDESTAL


SEE CAUTION 2



METER PEDESTAL SET CORRECTLY




METER CLEARANCES



CAUTION:
No gas meters within a 3' radius of meter enclosure

Place temporary underground service wire here (underground 30" deep)



CALL 48 HOURS BEFORE YOU DIG – Dial 811
It shall be the Member's responsibility to stay clear of all underground facilities.

Notes:

1. Member's facilities shall comply with Cooperative Standards, the NEC, and authorities having jurisdiction.
2. Meter pedestal shall be more than 3' from the mobile home.
3. The Member shall contact the Cooperative prior to the installation of the conduit system.
4. Cooperative owned or maintained underground service **shall not** be installed beneath a mobile home or any other structure.
5. The Member is responsible for clearing and maintaining all right of way.

UNDERGROUND SERVICE METER PEDESTAL INSTALLATION DETAILS

DRAWING 4.6-4

August 2010
NOT TO SCALE



First Electric
Cooperative Corporation